

Indorama Ventures Oxides Australia – Botany Manufacturing Site

Pollution Monitoring data (24 Dec 2022 – 23 Dec 2023)

EPA Licence 7494 Reporting Period

Requirement	Limit	Compliance Statement
<u>EPL Clause L2.2</u> Quantity of Hazardous and/or Liquid waste stored on the premise	< 1500te	Complied

Requirement	Limit	Monitoring Data
<u>EPL Clause L3</u> Noise emanating from all active plants in the BIP (Botany Industrial Park) premises	Day = 65 LAeq Evening = 55 LAeq Night = 50 LAeq	Compliance Report submitted as part of QENOS Pty Ltd Annual Return (Note: Reporting period is Oct 22 – Sep 2023)
<p>Complied. The following were noted.</p> <p>July 2023:</p> <ul style="list-style-type: none"> Point 8 background noise emissions observed between 50 – 51 dB(A) for the duration of the measurement which is marginally above the 50 dB(A) LA90 (15minute) criteria. Point 9 background noise emissions observed between 49 – 51 dB(A) for the duration of the measurement which is marginally above the 50 dB(A) LA90 (15minute) criteria. Point 10 background noise emissions estimate to be approximately 51 dB(A) for the duration of the measurement which is marginally above the 50 dB(A) LA90 (15minute) criteria. <p>As set out in Section 11.1.3 of the NSW EPA’s INP, a development is deemed to be in non-compliance with a noise consent or licence condition if the monitored noise level is more than 2dB(A) above the statutory noise limit specified in the consent or licence conditions. In each of the instances above, noise emissions were not more than 2dB(A) above the criteria.</p>		

Requirement	Limit	Compliance Statement
<u>EPL Clause L4</u> Must not cause or permit the emission of any offensive odour from the premises	None	There were no offensive offsite odour incidents attributable to our plant during the reporting period

Requirement	Reporting	Compliance Statement / Monitoring Data
<u>EPL Clause R4.1 – Leak Detection & Repair Program</u> Performance Report must be submitted to EPA as part of EPA Annual Return	To be submitted as part of EPA Annual Return	Submitted as part of EPA Annual Return.
<u>Summary of findings:</u>		

Number of tests points	5022
Number of Leaking Components	13 (1 of which was classified as a Major leak. Now repaired)
Total Product loss rate during monitoring period = 310 kg VOC/year (fugitive emissions)	

Requirement	Reporting	Compliance Statement / Monitoring Data									
<u>EPL Clause E2 & E4– Vent Management System Annual Test</u> Annual test must be done to ensure the Vent Management System (VMS) is operating in a proper and efficient manner	To be submitted as part of EPA Annual Return	Submitted as part of EPA Annual Return.									
Summary of findings:											
<table border="1"> <thead> <tr> <th>Component</th> <th>Licence Limit</th> <th>Test Result</th> </tr> </thead> <tbody> <tr> <td>Ethylene Oxide</td> <td>0.22 kg/hr</td> <td>< 0.001 kg/hr</td> </tr> <tr> <td>Propylene Oxide</td> <td>6.05 kg/hr</td> <td>< 0.001 kg/hr</td> </tr> </tbody> </table>			Component	Licence Limit	Test Result	Ethylene Oxide	0.22 kg/hr	< 0.001 kg/hr	Propylene Oxide	6.05 kg/hr	< 0.001 kg/hr
Component	Licence Limit	Test Result									
Ethylene Oxide	0.22 kg/hr	< 0.001 kg/hr									
Propylene Oxide	6.05 kg/hr	< 0.001 kg/hr									

Requirement	Reporting	Compliance Statement / Monitoring Data									
<u>EPL Clause E3 & E4 – Vent Management System Performance</u> Annual test must be done to ensure the Vent Management System (VMS) is operating in a proper and efficient manner	To be submitted as part of EPA Annual Return.	Submitted as part of EPA Annual Return.									
Summary of findings:											
There were no breakdowns or failure of the Vent Management System during the reporting period.											
<table border="1"> <thead> <tr> <th>Component</th> <th>Licence Limit</th> <th>Test Result</th> </tr> </thead> <tbody> <tr> <td>Conductivity</td> <td>> 80 microsiemens per cm</td> <td>Compliant</td> </tr> <tr> <td>Flowrate</td> <td>> 24 m3/hr</td> <td>Compliant with Clarification i.e. The report to the EPA includes clarification on 7 separate low flowrate conditions (pump tests, system test and stoppage during major turnaround)</td> </tr> </tbody> </table>			Component	Licence Limit	Test Result	Conductivity	> 80 microsiemens per cm	Compliant	Flowrate	> 24 m3/hr	Compliant with Clarification i.e. The report to the EPA includes clarification on 7 separate low flowrate conditions (pump tests, system test and stoppage during major turnaround)
Component	Licence Limit	Test Result									
Conductivity	> 80 microsiemens per cm	Compliant									
Flowrate	> 24 m3/hr	Compliant with Clarification i.e. The report to the EPA includes clarification on 7 separate low flowrate conditions (pump tests, system test and stoppage during major turnaround)									